



AFFILIATIONS:
 AMERICAN WATER WORKS ASSOCIATION
 AMERICAN SOCIETY FOR TESTING AND MATERIALS
 MICHIGAN GROUND WATER ASSOCIATION
 AMERICAN ACADEMY OF INDEPENDENT LABORATORIES
 WATER QUALITY ASSOCIATION
 SAFE DRINKING WATER FOUNDATION
 WATER ENVIRONMENT FEDERATION

Sample

TO: [REDACTED]
 RE: [REDACTED]
 WSSN: [REDACTED]

DATE: February 2, 2013
 SAMPLE NO: XX-123
 COLLECTED BY: [REDACTED]

ANALYTICAL REPORT

PARAMETER	EPA's MCL	Result	Your Sample Reading	Date/Time Sampled	Sample Location	Date/Time Analyzed	Analyst	Reporting Limit	Testing Method
1. Total Coliform Bacteria	0	Acceptable	Not detected	1/31/13 1p	Kitchen	1/31/13 3p	SC	1 cfu/100ml	9223B
2. E-Coli Bacteria	0	Acceptable	Not detected	1/31/13 1p	Kitchen	1/31/13 3p	SC	1 cfu/100ml	9223B
3. Nitrates	10 ppm	Acceptable	Not detected	1/31/13 1p	Kitchen	1/31/13 4:30p	SC	1 ppm	Hach10206
4. Nitrites	1 ppm	Acceptable	Not detected	1/31/13 1p	Kitchen	1/31/13 4:30p	SC	0.10 ppm	4500-NO2-B
5. Lead	15 ppb*	Acceptable	Not detected	1/31/13 1p	Kitchen	1/31/13 4:30p	SC	3 ppb	
6. Sodium	N/A	N/A	Not detected	1/31/13 1p	Kitchen	1/31/13 4:30p	SC	16.5 ppm	
7. Arsenic	10 ppb	Acceptable	Not detected	1/31/13 1p	Kitchen	1/31/13 4:30p	SC	3 ppb	Field
8. Turbidity	5 units	Acceptable	Not detected	1/31/13 1p	Kitchen	1/31/13 4:30p	SC	0 units	

* EPA Action Level

All analytical data, unless otherwise indicated, meets EPA drinking water criteria

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety. This report is for the use of the above addressed person and is for informational purposes only.